

## Membrane Element

## CAB3-8040

### Performance:

Permeate Flow:	4,500 gpd (17.0 m <sup>3</sup> /d)
Salt Rejection:	
Nominal	99.0 %
Minimum	98.5 %

### Type

Configuration:	Spiral Wound
Membrane Polymer:	Blend Cellulose Acetate
Nominal Membrane Area	340 ft <sup>2</sup>


### Application Data

Maximum Applied Pressure:	600 psig (4.14 MPa)
Feedwater Chlorine Concentration:	0.3 - 0.5 PPM (1.0 PPM maximum)
Maximum Operating Temperature:	104 °F (40 °C)
Feedwater pH Range:	4.0 - 6.0
Maximum Feedwater Turbidity:	1.0 NTU
Maximum Feedwater SDI (15 mins):	5.0
Maximum Feed Flow:	75 GPM (17.0 m <sup>3</sup> /h)
Minimum Ratio of Concentrate to Permeate Flow for any Element:	5:1
Maximum Pressure Drop for Each Element:	10 psi

### Test Conditions

The stated performance is initial (data taken after 30 minutes of operation), based on the following conditions:

2000 PPM NaCl solution  
420 psi (2.89 MPa) Applied Pressure  
77 °F (25 °C) Operating Temperature  
10% Permeate Recovery  
5.0 - 6.0 pH Range



Core tube ID = 1.125" (28.6 mm)

A, inches (mm)	B, inches (mm)	C, inches (mm)	Weight, lbs. (kg)
40.0 (1016)	7.95 (201.9)	1.50 (38.1)	36 (16.4)

**Notice:** Permeate flow for individual elements may vary + or - 15 percent. All membrane elements are supplied with a brine seal, interconnector, and o-rings. Elements are vacuum sealed in a preservative solution containing copper sulfate and glycerine, and then packaged in a cardboard box.

Hydranautics believes the information and data contained herein to be accurate and useful. The information and data are offered in good faith, but without guarantee, as conditions and methods of use of our products are beyond our control. Hydranautics assumes no liability for results obtained or damages incurred through the application of the presented information and data. It is the user's responsibility to determine the appropriateness of Hydranautics' products for the user's specific end uses.

8/17/98