



Capillary Ultrafiltration	Module	HYDRAcap80
---------------------------	--------	-------------------

Performance[†] $16.3 - 39.5 \text{ gpm } (3.7 - 9.0 \text{ m}^3/\text{h})$ Filtrate Flow:

≤ 0.07 NTU Filtrate Turbidity: Virus removal: ≥ 4 log ≥ 4 log Bacteria removal:

Type Configuration: Capillary Ultrafiltration Module

Membrane Polymer: Hydrophilic Polyethersulfone MWCO, nominal: 150,000 Daltons Nominal Membrane Area: 670 ft² (62.2 m²)

ID 0.031" (0.8 mm), OD 0.055" (1.4 mm) Fiber Dimensions:

Application Data[‡] $35 - 85 \text{ gfd } (59 - 145 \text{ l/m}^2/\text{h})$ Typical Filtrate Flux Range:

Maximum Applied Feed Pressure: 73 psig (5 bar) Maximum Transmembrane Pressure: 20 psig (1.4 bar)

Maximum Backwash Transmembrane Pressure: 20 psig (1.4 bar) Instantaneous Chlorine Tolerance: 100 ppm^{*}

Instantaneous Hydrogen Peroxide Tolerance: 200 ppm^{*} Maximum Chlorine Exposure: 100,000 ppm-hrs

Maximum Instantaneous Feed Turbidity: 100 NTU Maximum Operating Temperature: 104 °F (40 °C) pH Operating Range: 4.0 - 10.0


Cleaning pH Range: 1.5 - 13.0Operating Mode: Inside to Outside Filtration Direct flow or Crossflow

Typical Process Conditions

 $100 - 150 \text{ gfd } (170 - 255 \text{ l/m}^2/\text{h})$ Backwash Flux:

Backwash Duration: 30 - 60 seconds Backwash Frequency: 20 - 60 minutes Chemical Enhanced Backwash Frequency: 0 - 4 times per day Chemical Enhanced Backwash Duration: 1 - 30 minutes

Disinfection Chemicals: NaOCI, H2O2, CIO2 or NH2CI Cleaning Chemicals: HCI, H2SO4, NaOH or Citric Acid



A, inches (mm)	B, inches (mm)	C, inches (mm)	Pipe connections	Weight, lbs. (kg) ave.
83 (2108)	86 1/8 (2188)	87 1/4 (2216)	2" Victaulic	120 (54)

Certifications:

NSF61, CA-DHS and ETV-NSF Verification

For 15 minutes or less.

[†] Typical module performance for most feedwaters.

* The limitations shown here are for general use. The values may be more conservative for specific projects to ensure the best performance and longest life

Notice: Weight stated is shipping weight including 1L of a 0.95% solution of sodium bisulfite preservative.

Hydranautics believes the information and data contained herein to be accurate and useful. The information and data are offered in good faith, but without guarantee, as conditions and methods of use of our products are beyond our control. Hydranautics assumes no liability for results obtained or damages incurred through the application of the presented information and data. It is the user's responsibility to determine the appropriateness of Hydranautics' products for the user's specific end uses.



www.lenntech.com

info@lenntech.com Fax. +31-15-261.62.89

Tel. +31-15-261.09.00