





MODEL	A				VOLUME			DOME VOLUME			WEIGHT	
	mm	inch	+/-		liters	U.S. gal	cubic FT	liters	U.S. gal	cubic FT	Kg	LBS
			mm	inch								
16x65	1671	65.79	6	.24	194	51.3	6.86	9.15	2.42	0.32	18.65	41.03
16x52	1341	52.80	6	.24	153	40.4	5.41	9.15	2.42	0.32	15.65	34.47



- NOTES:
- TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD, LATEST REVISION.
  - OPERATING SPECIFICATIONS:
    - A. MAXIMUM WORKING PRESSURE - 150 PSI (10.5BAR)
    - B. TEMPERATURE RANGE - 34-120° F (1-49°C)
    - C. MAXIMUM VACUUM - 5"Hg (127mm Hg)
  - VISUAL LINER INSPECTION
    - A. NO MORE THAN 10 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS.
    - B. NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 3×3mm.
    - C. NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED.
  - ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED.
  - SURFACE TO BE FREE OF NICKS, SCRATCHES, RESIN AND GLASS.
  - SURFACE FINISH.
  - DIMENSIONS IN PARENTHESIS ARE REFERENCE ONLY.
  - DIMENSIONS IN SQUARE PARENTHESIS ARE INCH UNIT.
  - USING A STANDARD LEVEL WITH TANK POSITIONED ON A LEVEL SURFACE, DATUM B TO BE PARALLEL WITH DATUM A. BUBBLE OF LEVEL MUST FALL COMPLETELY WITHIN LINES WHEN MEASURED AT 90° INTERVALS.

**LENNTECH**  
info@lenntech.com Tel. +31-152-610-900  
www.lenntech.com Fax. +31-152-616-289

2		THIS DRAWING IS UPDATED COMPLYING WITH THE CHINESE VERSION				2008/07/21				
VERSION NO.		DESCRIPTION OF CHANGES:				SIGNATURE		DATE		
REFERENTIAL PLASTIC SHRINKAGE (IF NECESSARY):			<div> WAVE CYBER (SHANGHAI) CO., LTD.</div>							
SIGNATURE										
	NAME		DATE		SCALE		MATERIAL		MODEL	
DESIGN					1 : 5				DESCRIPTION	
INSPECTION					QUANTITY		SMOOTHNESS		16" (2.5") FRP PRESSURE VESSEL	
APPROVAL										
THIS PRODUCT DRAWING CAN NOT BE COPIED AND/OR USED WITHOUT PRIOR WRITTEN APPROVAL OF WAVE CYBER.			PROJECTION		COMPUTER CODE		DRAWING NO.		VERSION NO.	
							111161-00		2	
			DO NOT MEASURE THE DIMENSIONS.		UNIT: MM		TOTAL PAGE: 1			