


MODEL	A				VOLUME			DOME VOLUME			WEIGHT	
	mm	inch	+/- mm inch		liters	U.S.gal	cubic FT	liters	U.S.gal	cubic FT	Kg	LBS
24x72	1918	75. 51	15	0. 59	473	125. 0	16. 71	37. 95	10. 02	1. 34	54. 2	119. 2
24x65	1717	67. 60	15	0. 59	425	112. 3	15. 01	37. 95	10. 02	1. 34	50. 1	110. 2



NOTES:

- 1. TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD, LATEST REVISION.
- 2 . OPERATING SPECIFICATIONS:
 - A. MAXIMUM WORKING PRESSURE 150 PSI(10.5BAR)
 - B. TEMPERATURE RANGE $-34-120^{\circ} \text{ F}(1-49^{\circ}\text{C})$
 - C. MAXIMUM VACUUM 5"Hg (127mm Hg)
- 3 . VISUAL LINER INSPECTION
 - A. NO MORE THAN 10 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS.
 - B. NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 3×3mm.
- C. NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED.
- ${\bf 4}$. ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED.
- 5. SURFACE TO BE FREE OF NICKS, SCRATCHES, RESIN AND GLASS.
- 6. SURFACE FINISH.
- 7. DIMENSIONS IN PARENTHESIS ARE REFERENCE ONLY.
- 8 . DIMENSIONS IN SQUARE PARENTHESIS ARE INCH UNIT.
- 10. USING A STANDARD LEVEL WITH TANK POSITIONED ON A LEVEL SURFACE, DATUM B TO BE PARALLEL WITH DATUM A. BUBBLE OF LEVEL MUST FALL COMPLETELY WITHIN LINES WHEN MEASURED AT 90° INTERVALS.

6 VERSION NO.	THIS DRAWING IS UP	S	IGNATURE	2011/01/28 DATE					
REFERENTIAL NECESSARY):	. PLASTIC SHRINKAGE (IF							
	SIGNATURE		₩ WAVE CYBER (SHANGHAI) CO., LTD.						
	NAME	DATE	₩ W	AVE CYBER	(SHAL	NGHAI) CO.,	LID.		
DESIGN			SCALE	MATERIAL		MODEL			
INSPECTION			1:5			DESCRIPTION			
APPROVAL			QUANTITY	SMOOTHNESS		24"F	SURE VESSEL		
	DUCT DRAWING CAN NOT	DE				(SINC	(SINGLE OPENING)		
COPIED A	AND/OR USED WITHOUT F APPROVAL OF WAVE CYE	RIOR	PROJECTION	COMPUTER CODE		DRAWING NO. 111241-00		VERSION NO.	
			DO NOT MEASURE THE D	IMENSIONS.	UNIT: MM		TOTAL PAGE: 1		