

MODEL	VOLUME			DO	ME VOLUME	WEIGHT		
	liters	U. S. gal	cubic FT	liters	U.S.gal	cubic FT	Kg	LBS
30x72	704	186. 00	24. 88	72. 07	19. 03	2. 55	94. 4	207. 7

- 1. TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD, LATEST REVISION.
- 2 . OPERATING SPECIFICATIONS:
 - A. MAXIMUM WORKING PRESSURE 150 PSI(10.5BAR)
 - 34-150° F(1-65°C) B. TEMPERATURE RANGE
 - C. MAXIMUM VACUUM - 5"Hg (127mm Hg)
- 3 . VISUAL LINER INSPECTION
 - A. NO MORE THAN 20 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS.
 - B. NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 5×5mm.
 - C. NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED.
- 4 . ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED.
- 5 . SURFACE TO BE FREE OF NICKS, SCRATCHES, RESIN AND GLASS.
- 6 . SURFACE FINISH.
- 7 . DIMENSIONS IN PARENTHESIS ARE REFERENCE ONLY.
- 8 . DIMENSIONS IN SQUARE PARENTHESIS ARE INCH UNIT.
- 9. TANK TO BE BONDED TO BASE.
- 10. USING A STANDARD LEVEL WITH TANK POSITIONED ON A LEVEL SURFACE, DATUM B TO BE PARALLEL WITH DATUM A. BUBBLE OF LEVEL MUST FALL COMPLETELY WITHIN LINES WHEN MEASURED AT 90° INTERVALS WHEN PLACED ON THE TOP OF THE FLANGE.
- 11. AFTER THE TANK IS LEVELED, IT IS RECOMMENDED THAT THE TANK BE BOLTED TO THE FLOOR IN SIX POSITIONS PER THE TRIPOD BASE BOLT HOLE PATTERN WITH 3/8" ANCHORS.

6 D	6 DIMENSION A CHANGED								
5 T	5 THIS DRAWING IS UPDATED COMPLYING WITH THE CHINESE VERSION								
VERSION NO.			DESCRIPTION OF CHANGES:				IGNATURE	DATE	
REFERENTIAL P	LASTIC SHRINKAGE (TF							
NECESSARY):									
ADOLOGIST(1)									
SIGNATURE			₩ WAVE CYBER (SHANGHAI) CO., LTD.						
	NAME	DATE	₩.	AVE CYBEK	(SHAL	NGHAI) CO.,	LID.		
DESIGN			SCALE	MATERIAL		MODEL			
INSPECTION			1 : 10			DESCRIPTION			
APPROVAL			QUANTITY	SMOOTHNESS		30" FRP PR	ESSURE	VESSEL	
111111111111111111111111111111111111111			-			(SINGLE FL	ANGE OF	PENING)	
THIS PRODUCT DRAWING CAN NOT BE COPIED AND/OR USED WITHOUT PRIOR WRITTEN APPROVAL OF WAVE CYBER.						,		,	
			PROJECTION	COMPUTER CODE		DRAWING NO.		VERSION NO.	
			ı (⊕		1133		1-00	6	
			DO NOT MEASURE THE DIMENSIONS.		UNIT:	UNIT: MAM TO		FOTAL PAGE: 1	