




MODEL									A (mm)	B (mm)	C (mm)	D (mm)	(E) (mm)
	liters	U.S. gal	cubic FT	liters	U.S. gal	cubic FT	Kg	LBS					
36x72	998	263.6	35.2	125.8	33.21	4.44	139.7	308	2213±15	1153	520	910	(783)
36x57	776	205	27.4	125.8	33.21	4.44	118.5	261	1913±15	855	520	560	(833)



- NOTES:
- 1. TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD, LATEST REVISION.
 - 2. OPERATING SPECIFICATIONS:
 - A. MAXIMUM WORKING PRESSURE - 150 PSI (10.5 BAR)
 - B. TEMPERATURE RANGE - 34-150° F (1-65°C)
 - C. MAXIMUM VACUUM - 5" Hg (127 mm Hg)
 - 3. VISUAL LINER INSPECTION
 - A. NO MORE THAN 20 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS.
 - B. NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 5×5 mm.
 - C. NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED.
 - 4. ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED.
 - 5. SURFACE TO BE FREE OF NICKS, SCRATCHES, RESIN AND GLASS.
 - 6. SURFACE FINISH.
 - 7. DIMENSIONS IN PARENTHESIS ARE REFERENCE ONLY.
 - 8. TANK TO BE BONDED TO BASE.
 - 9. USING A STANDARD LEVEL WITH TANK POSITIONED ON A LEVEL SURFACE, DATUM B TO BE PARALLEL WITH DATUM A. BUBBLE OF LEVEL MUST FALL COMPLETELY WITHIN LINES WHEN MEASURED AT 90° INTERVALS WHEN PLACED ON THE TOP OF THE FLANGE.
 - 10. AFTER THE TANK IS LEVELED, IT IS RECOMMENDED THAT THE TANK BE BOLTED TO THE FLOOR IN SIX POSITIONS PER THE TRIPOD BASE BOLT HOLE PATTERN WITH 3/8" ANCHORS.



info@lennotech.com Tel. +31-152-610-900
www.lennotech.com Fax. +31-152-616-289

0		FIRST VERSION							
VERSION NO.		DESCRIPTION OF CHANGES:				SIGNATURE		DATE	
REFERENTIAL PLASTIC SHRINKAGE (IF NECESSARY):									
SIGNATURE		WAVE CYBER (SHANGHAI) CO., LTD.							
NAME		DATE		SCALE		MATERIAL		MODEL	
DESIGN		Jed Cao 2013.12.12		1 : 10				DESCRIPTION	
INSPECTION		Tom Tang 2013.12.12						36" FRP PRESSURE VESSEL (SIDE FLANGE OPENING) - (DIN)	
APPROVAL		Tom Tang 2013.12.12		QUANTITY		SMOOTHNESS		DRAWING NO.	
								110623-00	
				PROJECTION		COMPUTER CODE		VERSION NO.	
								0	
THIS PRODUCT DRAWING CAN NOT BE COPIED AND/OR USED WITHOUT PRIOR WRITTEN APPROVAL OF WAVE CYBER.				DO NOT MEASURE THE DIMENSIONS.		UNIT: MM		TOTAL PAGE: 1	