

Product Information Sheet

ADVANTAGES

- Concentrated liquid formulation designed for use as a low pH cleaner of polyamide thin film composite membrane surfaces
- Removes inorganic carbonate, phosphate and sulfate scalants as well as metal oxides
- Contains a synergistic blend of cleaners and scale removal agents for a thorough cleaning of the membrane
- Will remove certain inorganic precipitants that cannot be removed through the use of citric or hydrochloric acid
- May eliminate the need for repeat cleanings in cases of severe scaling
- Compatible with all Thin Film Composite R.O. membranes from all major membrane suppliers
- Certified by NSF to NSF/ANSI Standard 60

TYPICAL PROPERTIES

Appearance	Clear colorless to yellow liquid
Odor	Essentially no odor
Solubility in water	Complete
pH (as is) @ 25°C	< 2
Specific Gravity	1.15 ± 0.05

PACKAGING

5 gallon pails, 55 gallon non-returnable plastic drums and 275 gallon totes

LENNTECH

info@lennotech.com Tel. +31-152-610-900
www.lennotech.com Fax. +31-152-616-289

AWC[®] C-234

Reverse Osmosis Membrane Cleaning Compound

SAFETY & HANDLING

Store in cool, dry and well ventilated area. Keep containers closed. Wash contaminated clothes before re-use. Wash thoroughly after handling. For more information, see the Safety Data Sheet provided with this product.

CHEMICAL FEEDING AND CONTROL

The cleaning solution should be prepared using potable water that is free of residual chlorine or other oxidizing agents. Add 2 gallons of AWC C-234 to every 100 gallons of water (2% solution). Adjust the pH in the range 2–3. Recirculate the cleaning solution throughout the system, after redirecting the first 20% of the solution to drain. Do not exceed pressures, temperatures and flow rates recommended by the membrane manufacturer. Cleaning efficacy can be further improved by heating the cleaning solution and alternately circulating the solution for 15 minutes and then soaking the membranes for 15 minutes. Repeat as necessary. Monitor the pH range periodically throughout the cleaning. When pH increases above the desired range, it should be adjusted by adding more AWC C-234.

