

info@lenntech.com Tel. +31-152-610-900 www.lenntech.com Fax. +31-152-616-289

LENNTECH

SPECIFICATIONS

:

General Features	Permeate flow rate: Stabilized salt rejection: Effective membrane area:	800 GPD (3.0 m³/day) 99.7% 27 ft² (2.5 m²)			
	1. The stated product performance is based on data taken after 30 minutes of operationat the followingtest conditions:				
	 2,000 mg/L NaCl solution 15% recovery 77 ∘F (25 ∘C) pH 6.5 –7.0 	at 225 psig (1.5 MPa) applied pressure			
	 Minimum salt rejection is 99.4%. Permeate flow rate for each element mayvary but will be no more than 15%. All elements are vacuum sealed in a polyethylene bag containing 1.0% SBS (sodium bisulfite) solution and individuallypackaged in a cardboard box. 				
	Membrane type: Membrane material: Element configuration:	Thin-Film Composite Polyamide(PA) Spiral-Wound, FRP W rapping			

Dimensions

	A	В	С	D	E	Part Number	
Model Name						Inter - connector	Brine Seal
RE 2540-FE ⁿ	40.0 inch (1,016 mm)	2.5 inch (64 mm)	0.75 inch (19.1 mm)	1.1 inch (28 mm)	1.1 inch (28 mm)	40000305	40000223



1. Each membrane elementsupplied with one brine seal, one interconnector (coupler) and four o-rings.

2. All RE2540 elementsfit nominal2.5 inch (64 mm) I.D. pressure vessels.

The information provided in this document is solely for informative purposes. It is the user's responsibility to ensure the appropriate usage of this productWoongjin Chemical assumes no obligation, liability or damages incurred for the misuse of the product or for the information provided in this documentThis document does not express or implies any warranty as to the merchantability or fitness of the product.

RE 2540 - F Eⁿ

:

Enhanced fouling resistant RO element for brackish water and wastewater reuse



APPLICATION DATA

Operating Limi ts	Max. Pressure Drop / Element	15 psi (0.1 MPa) 60 psi (0.41 Mpa)		
	 Max. Pressure Drop / 240" Vessel 			
	 Max. O peratingPressure 	600 psi (0.42 MPa)		
	 Max. Feed Flow Rate 	6 gpm (1.36 m³/hr)		
	 Min.Concentrate Flow Rate 	1 gpm (0.23 m³/hr)		
	 Max. O peratingTemperature 	113 °F (45 °C)		
	 Operating pH Range 	2.0–11.0		
	· CIP pH Range	1.0–13.0		
	· Max.Turbidity	1.0 NTU		
	• Max.SDI (15 min)	5.0		
	Max. Chlorine Concentration	< 0.1 mg/L		
Design Guidelines for Various	• Waste water Conventional (SDI < 5)	8–12 gfd		
Water Sources	• Wastewater Pretreated by UF/MF (SDI < 3)	10–14 gfd		
	• Seawater, Open Intake (SDI < 5)	7–10 gfd		
	• Seawater, Beach Well (SDI < 3)	8–12 gfd		
	• SurfaceWater (SDI < 5)	12–16 gfd		
	• SurfaceW ater (SDI < 3)	13–17 gfd		
	• Well water (SDI < 3)	13–17 gfd		
	• RO permeate (SDI < 1)	21–30 gfd		
Saturation Limits	Langlier Saturation Index(LSI)	<+1.5		
(Using Antiscalants) [†]	Stiff and Davis Saturation Index(SDSI)	<+0.5		
	· CaSO 4	230% saturation		
	· SrSO ₄	800% saturation		
	· BaSO4	6,000% saturation		
	· SiO ₂	100% saturation		
	[†] The above saturation limits are typically accepted by proprietary antiscalant manufacturers. It is the user's responsibility to ensure proper chemical(s) and concentration are dosed ahead of the membrane systemto prevent scale formation anywhere within the membrane system. Membrane elements fouled or damaged due to scale formation are not covered by the limited warranty.			

GENERAL HANDLING PROCEDURES

Elements contained in the boxes must be kept dry at room temperature $(7-32^{\circ}C; 40-95^{\circ}F)$ and should not be stored in direct sunlight. If the polyethylene bag is damaged a new preservative solution (sodium bisulfite) must be added and airtight sealed to prevent drying and biological growth.

Permeate from the first hour of operation should be discarded to flush out the preservative solution.

Elements should be immersed in a preservative solution during storage, shipping and system shutdowns to prevent biological growth and freezing. The standard storage solution contains 1% by weight sodium bisulfite or sodium metabisulfite (food grade). For short term storage (i.e. one week or less) 1% by weight sodium metabisulfite solution is adequate for preventing biological growth. Keep elements moist at all times after initia wetting.

Avoid excessive pressure and flow spikes.

Only use chemicals compatible with the membrane elements and components. Use of such chemicals may void the element limited warranty.

Permeate pressure must always be equal or less than the feed/concentate pressure. Damage caused by permeate back pressure voids the element limited warranty.