

## Water Technologies & Solutions fact sheet

# Kleen\* MCT107

## membrane cleaner

### description and use

Kleen MCT107 is a neutral pH liquid formulation designed specifically to remove organic foulants, silt and other particulate deposits from cellulose acetate reverse osmosis membranes. This highly effective product provides superior cleanings resulting in longer system running time.

### typical applications

During the operation of a membrane separation system, organic materials and suspended solids in the incoming water can accumulate on the membrane surface. Fouling from these species impedes the flow of water through the membrane. This can result in unacceptably low production, high operating pressure, or an excessive pressure drop in the system. Additionally, the accumulation of scale next to the membrane surface can increase the amount of dissolved material passing through the membrane, resulting in product water of unacceptable quality. Before the scale accumulates to a level where product water quality declines or membrane damage can occur, it should be removed through a clean-in-place (CIP) off-line cleaning. Indications of the need for cleaning include a significant decrease in normalised permeate flow, a significant increase in pressure drop across the system (or individual stage), or an increase in the normalised salt passage such that product quality is unacceptable. Your SUEZ representative can assist you with monitoring your system and determining when cleaning is advised.

### treatment and feeding requirements

**Feed System** – This product should be used in conjunction with the membrane cleaning equipment supplied by the manufacturer of the membrane system.

If such system is not present, contact your SUEZ representative for information on fabricating or obtaining a cleaning system.

**Dilution** – The product must be diluted prior to introduction into the membrane system. The recommended dilution for this product is 1 – 3 % by weight.

**Materials Compatibility** – Corrosion-resistant equipment, such as PVC, should be used for the storage and preparation of this product. Pumping materials coming in contact with the diluted products should also be corrosion resistant

### general cleaning instructions

The following general cleaning procedure can be followed. For the optimum cleaning procedure for your system, contact your SUEZ representative.

1. Inspect cleaning tank, hoses, and cartridge filters. Clean tank and flush hoses if necessary. Install new cartridge filters.
2. Fill cleaning tank with RO permeate or demineralised water. Turn on agitator or pump recirculation.
3. Slowly add Kleen MCT107 to cleaning tank (1 to 3 kg product per every 100 liter of water) and allow to mix thoroughly.
4. Check solution temperature. If solution temperature is lower than recommended, adjust heating control to provide optimum temperature. If manufacturer's recommendation is not available, contact your SUEZ representative.

**LENNTECH**

info@lenntech.com Tel. +31-152-610-900  
www.lenntech.com Fax. +31-152-616-289

5. Check solution pH. The solution pH should be 6.5 - 7. If pH is too low, adjust pH upward with NaOH, or other chemical as recommended by the membrane manufacturer. If pH is too high, adjust with hydrochloric acid.
6. Circulate solution through one stage at a time in the direction of feed flow for 30 minutes. Circulate at the flow rate recommended by the membrane or system manufacturer. If the manufacturer's recommendation is not available, contact your SUEZ representative. Pressure should be low enough so that no permeate is produced during cleaning, but always less than 4 barg. In cases of heavy fouling, the first return flow (up to 15 % of the cleaning tank volume) should be diverted to drain to prevent redeposition of removed solids. For optimum results, each stage must be cleaned separately in a multistage system.
7. If the first stage cleaning solution becomes turbid or discoloured, dump the tank and prepare a fresh cleaning solution before proceeding. If solution pH or temperature moves out of the recommended range, a new solution should be prepared. In any event, a new cleaning solution should be prepared for each stage.
8. Rinse with RO permeate before returning system to service.
9. When returning unit to service, divert product water to drain until any residual cleaning solution has been rinsed from the system.

### packaging information

Kleen MCT107 is a liquid blend and is available in a wide variety of customised containers and delivery methods. Contact your local SUEZ representative for details.

### safety precautions

A Material Safety Data Sheet containing detailed information about this product is available on request.

**LENNTECH**

info@lennotech.com Tel. +31-152-610-900

www.lennotech.com Fax. +31-152-616-289